

Attestation

BREEAM International

On 23 July 2019, Eurofins Product Testing A/S received a sample of a MDF board with the product name:

MDF Standard (20 mm)

supplied by

Sonae Arauco Deutschland GmbH

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards specified in Indoor Air Comfort GOLD version 6.0: EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (See test report no. 392-2019-00281601_A_EN).

Evaluation of the emission results according to the basic level emission criteria (table 17) of: BREEAM Int.: Hea 02 Indoor air quality:

- Carcinogenic substances were not detectable after 28 days ($< 0.001 \text{ mg/m}^3$)
- The sum of VOC ("TVOC") after 28 days was below the limit of 1.0 mg/m^3
- Formaldehyde after 28 days was below the limit of 0.08 mg/m^3

The tested product complies with the requirements of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor air quality (version SD233 issue 2.0 of July 2019).

12 August 2020



Janne Rothmann Norup
Analytical Service Manager